



CERTIFICATE No. 22/5105/00/0161

PPE TYPE SET

REF: CALEÇON, T-SHIRT, CAGOULE ET PROTECTEUR DE COU ARC-10





AITEX, Notified Body No. 0161 for the application of Regulation (EU) 2016/425 of the European Parliament and of the Council of 9th March 2016, in which the essential health and safety requirements that Personal Protective Equipment (PPE) must comply with.

CERTIFIES The Company:

SIBILLE FAMECA ELECTRIC 815B, CHEMIN DU RAZAS-ZI-LES PLAINES FR-26780 MALATAVERNE

As a manufacturer





CERTIFICATE No. 22/5105/00/0161

Has obtained EU TYPE EXAMINATION in compliance with what is set out in Annex V (module B) in Regulation (EU) 2016/425 and in agreement with the applicable test procedures and technical specifications

Designed for the protection of the entire body with the exception of face, hands and fee, according to the following standard/s:

- EN ISO 13688:2013 General requirements.
- EN ISO 11612:2015 against thermal risks of limited flame spread (A1, A2); Convective Heat (B1), Radiant heat (C1) and Heat by contact (F1).
- IEC 61482-2:2018 against the risk of burn provoked by an electrical arch of 4kA (APC= 1) according the standard EN 61482-1-2:2014.

Tests carried out after 5 washing cycles 30°C

Having achieved the performance requirements specified in conformity assessment report No. **2022EP0586UE** and the PPE's Technical Documentation.

Description of the PPE:

Set T-shirt, trousers, neck and balaclava set made in navy blue knitted fabric.

The materials that form the PPE, are described in the conformity assessment report nº 2022EP0586UE.

The PPE is available with the following variants:

- It can be manufactured in all the colours included in the range certified by Oeko-Tex
- The balaclava can be manufactured with an opening on the face. Both executioners may be presented in a short or long version
- It can be manufactured with long neck

It shall be the manufacturer's responsibility to provide specific information of this certificate and the tested levels of protection.

The CAT. III PPE shall only be used in conjunction with one of the conformity assessment procedures according to module C2 or module D described in article 19 letter c) of the Regulation (EU) 2016/425.



Silvia Devesa Valencia Laboratory Subdirector and Innovation